

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-1076:143 Page 1 of 1

CATEGORY: Heat Detectors

LISTEE: Kidde-Fenwal, Inc., 400 Main Street, Ashland, MA 01721
Contact: Terrill Garland (508) 881-2000

DESIGN: Model THD-7252 fixed temperature/rate compensation type heat detector. Refer to listee's data sheet for additional detailed system description and operational considerations.

RATING: Electrical: 16.5 - 27.5 VDC
Temperature: 135°F - 145°F

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as fix temperature/rate compensated heat detector for use with Listee's separately listed Model Fenwalnet 2000 (CSFM Listing No. 7165-1076:141) or Pegasys (CSFM Listing No. 7165-1076:146) fire alarm control units.

09-06-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 12, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager